

2019 NEWEA, NEBRA, and MWPCA Biosolids Conference

Initial Co-Digestion Feasibility Study at the Rockland WWTP



October 17, 2019 - Springfield, MA







Rockland, MA Case Study

Rockland, MA WRRF

- Managed by Town of Rockland Sewer Dept (SUEZ contract ops)
- Avg. Annual Flow: 2.5 MGD
- One of six WRRFs with AD in Mass





MassCEC Organics-to-Energy Program

- Supports the development of facilities that convert sourceseparated organic materials and sewage sludge into heat, electricity and/or compressed natural gas
- Published >10 studies since program creation in 2012
- Three stages of funding
 - Feasibility Study

Max Grant Level: \$60K

- Technical Study
- Implementation and Pilot Project



Co-digestion opportunities at smaller WRRFs

Electricity generation from WRRF sludge with MAD + ICE			
2	.5 MGD / 2.5 DTPD	+65 kW	
WRRF Electricity Usage, kWh/MG	Remaining Electricity Demand (Annual Avg), kW	Trucks /d to achieve 100% Elec. Neutrality*	
1,200	60	1	
1,500	95	1.5	
1,800	125	2	

* Assumes 6k gallon tanker truck, FOG liquid waste at 5% TS

Co-digestion opportunities at smaller WRRFs



* Assumes 6k gallon tanker truck, FOG liquid waste at 5% TS

Looking past increased gas production





Co-digestion feasibility study framework



Plant Operations Current Conditions/Benchmarking



Residuals Management Limited by existing state of equipment

- Current residuals generation: ~5 wtpd at 19%TS using belt filter press
- Difficult to maintain digestion temperatures required for Class B requirements
 - Co-settled PS and WAS feed is relatively thin (~2.4% TS) and variable given seasonal loading
- Hauled under long-term agreement to multiple disposal sites (incineration and landfill)
 - At time of study: \$100/ton, has since increased to \$111/ton

Plant Operations State-of-good-repair projects required

- Mechanical WAS Thickening
 - Unlock digester capacity, control heat load
- Digester Rehabilitation
 - Covers, heat, mixing
- Digester Gas Management
 - Update to design codes and standards
 - Provide short-term storage
 - Change out all CS piping
- Blend tank
 - Homogenize loading to digester

Plant Operations

Project scope evaluated at varying scales



* Assumes 6k gallon tanker truck, FOG liquid waste at 5% TS

Tipping Fees Organics Market Assessment





- Targeted outreach to 16 potential, liquid HSW sources
 - **Primary Generators:** production/ manufacturing facilities
 - Indirect Sources: hauling companies/brokers
- Typical Liquid HSW Sources
 - Hydrophilic Non Oily
 - Expired soda, whey, food/ beverage production
 - Hydrophobic Oily
 - DAF waste, dairy/meat processing waste, FOG

Tipping Fees Positive response from 16 potential sources

- Interest gauged on specific drivers
 - Cost reduction
 - Disposal reliability
 - Sustainability initiatives
- Results
 - Significant interest current market for rate of disposal of organic wastes ranges from \$0.06 to \$0.10 per gallon, depending on waste type

Biogas Utilization Universe of Alternatives



Generate Power and Heat On-Site

- Gas Turbine Generators
- IC Engine Generators
- Fuel Cells
- Microturbines
- Stirling Cycle Engines
- Organic Rankine Cycle

Biogas Uses



- Boiler/Heat (hot water, steam)
- Product drying (via steam, hot air/oil/water)



Off-Site Sale/Use

- "As-Is" Unscrubbed
- Scrub CO₂, biomethane pipeline injection
- Scrub CO₂, Vehicle Fuel (rCNG)

Biogas Utilization

Kilowatts, therms, gallons ... How do you compare value?

Relative value of energy (adjusted for conversion efficiency)



Rockland goal: onsite power generation

- Gas upgrading introduced too many variables at this stage

Biogas Utilization Projecting value of onsite power generation

- Parse apart usage charge from power bill (\$0.14/kWh)
 - Disregard non-bypassable and standby charges
 - Potential to limit demand charge
- Calculate value from electricity export
 - National Grid has met net metering quota in area
 - Electricity sold back at wholesale rate of \$0.035/kWh
- Consider opportunities for regional and state incentives
 - National Grid Power Offset: \$0.075/kWh
 - REC value determined under Renewable Portfolio Standard

Biogas Utilization Renewable Portfolio Standard

- Requirement on retail electric suppliers to provide a minimum percentage or amount of their retail load with eligible sources of renewable energy
- Renewable energy certificate (REC) program to facilitate compliance
 - NE states participate in a single power pool



REC value projected at all-time low at time of study (\$0.005/kWh). MA and ME have since increased RPS targets/ demand.

First Cut Financial Evaluation 20-Yr NPV shows counter-intuitive results



What's limiting O&M benefits? Residuals Management Costs increase



Impact of Revenue Limited with electricity export

Revenue	Planning Baseline	Alt A: No Organics	Alt B: Moderate Organics	Alt C: Aggressive Organics
Annual Avg. Production	0	80 kW	300 kW	500 kW
Electricity Offset/ Sale	\$0	\$220,000	\$440,000	\$580,000
Organics Tipping Fees	\$0	\$0	\$370,000	\$770,000

These are rough estimates based on experience. The ultimate values may vary a little or moderately depending on regulatory impacts, inflation or local impacts.

Tipping fee increases provide better alingment





Substantial swing in economics available with improved residuals management costs

Comparison of Alt C (30k gpd) to Do-Nothing

	Residuals Management Cost (\$/wet ton)				
		\$100 (Raw disposal)	\$80 (Class B)	\$60 (Class B)	
Feedstock %VS / %VSR	85% / 85%	+\$4.9M	+\$3.4M	+\$2.0M	
	90% / 90%	+\$1.6M	+\$0.6M	-\$0.3M	
	95% / 95%	-\$1.8M	-\$2.4M	-\$2.8M	

Conclusions

- Plant Operations
 - Co-digestion requires integration with state-of-good-repair projects
- Tipping Fees
 - Economics impacted by HSW disposal market; saw interest in project with some variability in pricing
- Biogas Utilization
 - With power generation, revenue limited with electricity export
- Residuals Management
 - Improved residuals management rate with readily degradable feedstocks required for favorable economics at increased HSW loading

Acknowledgements



Town of Rockland

John Loughlin Superintendent Rick Kotouch Plant Ops PM (SUEZ) Ed Mcauliffe Plant Ops (SUEZ)

Brown and Caldwell

Chris Muller Principal Engineer Natalie Sierra Senior Review Tracy Chouinard Process Model Lead Alison Nojima Energy Lead Camilla Kuo-Dahab Sidestream impacts



Thank you

John Ross, PE jross@brwncald.com T 978.983.2030 | C 617.383.4962

